SHEET NUMBER															ITEM	ITEM EXT.	GRAND TOTAL	UNIT	DESCRIPTION	SEE SHEET NO.
OFFICE CALCS														196						
																			PAVEMENT	
312															251	01000	312	SY	PARTIAL DEPTH PAVEMENT REPAIR (441)	
4140															253	01000	4140	SY	PAVEMENT REPAIR	
9005															255	10011	9005	SY	FULL DEPTH PAVEMENT REMOVAL AND RIGID REPLACEMENT, CLASS QC1, AS PER PLAN	P.16
2894															255	10161	2894	SY	FULL DEPTH PAVEMENT REMOVAL AND RIGID REPLACEMENT, CLASS QC MS, AS PER PLAN	P.16
34828															255	20000	34828	FT	FULL DEPTH PAVEMENT SAWING	
17759															304	20000	17759	CY	AGGREGATE BASE	
3892															305	13010	3892	SY	9" CONCRETE BASE, CLASS QC 1P	
127															407	10000	127	GAL	TACK COAT	
5813															408	10000	5813	GAL	PRIME COAT	
1029															451	14011	1029	SY	9" REINFORCED CONCRETE PAVEMENT,CLASS QC 1P,AS PER PLAN	P.12
31690															451	15011	31690	SY	10" REINFORCED CONCRETE PAVEMENT,CLASS QC 1P, AS PER PLAN	P.12
6783															452	13011	6783	SY	9" NON-REINFORCED CONCRETE PAVEMENT,CLASS QC 1P,AS PER PLAN	P.12
50342															452	19001	50342	SY	VARIABLE THICKNESS NON-REINFORCED CONCRETE PAVEMENT, AS PER PLAN	P.12
																			WATER WORK	
														3649	638	02504	3649	FT	12" WATER MAIN DUCTILE IRON PIPE ANSI CLASS 53, MECHANICAL JOINTS AND FITTINGS	
														2481	638	02604	2481	FT	12" WATER MAIN DUCTILE IRON PIPE ANSI CLASS 53, BOLTLESS-RESTRAINED JOINTS AND FITTINGS	
														2107	638	02700	2107	FT	12" WATER MAIN DUCTILE IRON PIPE ANSI CLASS 55, BALL AND SOCKET JOINTS AND FITTINGS	
														1142	638	02730	1142	FT	12" WATER MAIN POLYVINYL CHLORIDE PIPE AND FITTINGS, AWWA C900 DR18	
														1608	638	02800	1608	FT	12" WATER MAIN POLYVINYL CHLORIDE PIPE AND FITTINGS, ASTM SDR 26	
														438	638	04800	438	FT	¾" COPPER SERVICE BRANCH	
														464	638	05300	464	FT	¾" POLYETHYLENE SERVICE BRANCH	
														212	638	06704	212	FT	20" STEEL PIPE ENCASEMENT, OPEN CUT	
														310	638	07310	310	FT	24" STEEL PIPE ENCASEMENT, BORED OR JACKED	
														18	638	08100	18	EACH	12" GATE VALVE AND VALVE BOX	
														16	638	09200	16	EACH	12" CUTTING-IN SLEEVE, VALVE AND VALVE BOX	
														12	638	09700	12	EACH	12" X 6" TAPPING SLEEVE, VALVE AND VALVE BOX	
														36	638	10200	36	EACH	6" FIRE HYDRANT	
														10	638	10300	10	EACH	FIRE HYDRANT EXTENDED AND ADJUSTED TO GRADE	
														8	638	10500	8	EACH	FIRE HYDRANT REMOVED AND RESET	
														8	638	10600	8	EACH	FIRE HYDRANT AND GATE VALVE REMOVED AND RESET	
														12	638	10800	12	EACH	VALVE BOX ADJUSTED TO GRADE	
														6	638	10900	6	EACH	SERVICE BOX ADJUSTED TO GRADE	
														4	638	11100	4	EACH	METER AND CHAMBER REMOVED AND RESET	

GENERAL SUMMARY

DESIGN AGENCY

DESIGNER
JKP

REVIEWER
FGW 01/17/25

PROJECT ID
130703

SHEET P.80 TOTAL 267

TRU-99-13.48

MODEL: SP1307-3b PAPERSIZE: 34x22 (in.) DATE: 1/17/2025 TIME: 8:00:00 AM
pw:\\ohiodot-pw.bentley.com:ohiodot-pw-02\Documents\03 Standards\Sample Plans\02-Working\SP1307-3b.dgn