

Form Name:	ADA Waiver
Submission Started:	July 3, 2025 9:20 am
Browser:	Chrome 138.0.0.0 / Windows
IP Address:	156.63.69.215
Unique ID:	1358940434
Request ID:	#2474
Submission Completed:	July 7, 2025 2:51 pm
Process Time:	4 day(s), 5 hour(s), 31 minute(s), 5 second(s)
Participant(s):	Laura Beese (D4)
Location:	39.9625, -83.0061

ADA Waiver

Variance Submitted By	Sean Hayes
Submitter Email	Sean.Hayes@dot.ohio.gov
Phone	13307864814
District	District 4
District Design Engineer	Laura.Beese@dot.ohio.gov

ADA Variances Section

PID	119106
CRS	STA-30/VAR-13.15/VAR
Unique ADA Ramp ID	RMP0029757
Ramp Type	Parallel
Proposed Modification	No Change to Existing Ramp
Project Development Plan (PDP) Phase	Design
Date/Time	Jul 03, 2025
Ramp Slope % (Exist)	8.30
Cross Slope (Exist)	3.00
Ramp Width (Exist)	5.00
Landing Length (Exist)	4.50
Landing Width (Exist)	5.00
Landing Cross Slope (Exist)	2.90

Waiver Details

Project Scope

SR 30/ Short St - Ramp D

Resurfacing of STA US 30 (a portion in the City of Canton) and SR 172, including minor bridge work to several structures, installing safety improvements on SR 183 including a mid-block crossing with solar Rectangular Rapid Flashing Beacons, static pedestrian crossing warning signs and landing pads with truncated domes, in the Villages of East Canton and Minerva (Part 1). Signal installation at US30 Ramp and Raff Rd and new Overhead Sign assembly near SLM 19.09 (Part 2).

Support for Deviation

Landing Slope 8.9%

SR 30 slope and matching existing parking lot forces non-compliance

Attach Photo<https://www.formstack.com/admin/download/file/18203909124>

Attach Location Map<https://www.formstack.com/admin/download/file/18203909126>

District Approval

District Waiver Request Approval YES

District Design Engineer Name Laura M. Beese

District Design Engineer Signature