

SPECIAL NOTES

6. DURING INSTALLATION, THE BRICK IS TO BE RESET IN REASONABLY CLOSE CONFORMITY TO THE PATTERN OF THE EXISTING BRICK PAVEMENT ON A SETTING BED OVER ITEM 305 CONCRETE BASE. THE SETTING BED FOR HISTORICAL BRICK STREETS SHALL CONSIST OF 1 INCH OF SAND; WHEREAS, 3/4-INCH BITUMINOUS SETTING BED FOR NEWER STYLE ROADWAY PAVERS. THE CONCRETE BASE THICKNESS SHALL MATCH THE EXISTING BASE OR A MINIMUM OF 7 INCHES.
- 6A. HISTORICAL BRICKS WITHOUT SPACING LUGS: THE MAXIMUM WIDTH OF A BRICK JOINT SHALL BE 1/2 INCH. THIS RESTRICTION SHALL ALSO APPLY TO THE JOINT FORMED ADJACENT TO THE PERIMETER OF A REPAIR AREA, WHERE THE ROWS MAY NOT BE PARALLEL TO ONE ANOTHER. ALL JOINTS SHALL BE FILLED WITH POLYMERIC SAND FROM THE APPROVED MATERIALS LIST FOLLOWING MANUFACTURER'S INSTRUCTIONS. THIS MAY REQUIRE MORE THAN ONE APPLICATION. FURTHER, MECHANICAL VIBRATION WILL BE REQUIRED FOR CONSOLIDATION OF DRY MORTAR MIX.
- 6B. NEWER STYLE ROADWAY PAVERS: INSTALLATION AND MATERIALS SHALL MEET WITH THE REQUIREMENTS OF COLUMBUS SUPPLEMENTAL SPECIFICATION 1524.

PAVEMENT & UTILITY CUT REPAIR STANDARDS

CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC SERVICE
DIVISION OF DESIGN AND CONSTRUCTION

STD DWG

1441

4/22/2019

SHT 7 OF 13