


FILE NAME: 2788-06

**NOTE:**  
 1.5'-0" MINIMUM OF UNDISTURBED EARTH FROM THE FACE OF THE POLE TO THE TRENCH WALL MUST BE MAINTAINED OR THE POLE MUST BE TEMPORARILY SUPPORTED BY THE EFFECTED UTILITY. (THIS IS NOT A PAY ITEM)

THIS DOCUMENT IS THE PROPERTY OF GRW ENGINEERS, INC. AND SHALL NOT BE REPRODUCED IN WHOLE OR IN PART OR USED FOR CONSTRUCTION OF OTHER THAN THIS SPECIFIC PROJECT WITHOUT WRITTEN PERMISSION OF GRW ENGINEERS, INC.

NO.	DESCRIPTION	DATE	BY



GRW PROJECT NO. 2788

**LINE "A"**  
 STA. 48+43 TO STA. 63+50  
 EASTERN TRANSMISSION LINE #2  
 AVON LAKE MUNICIPAL UTILITIES

DESIGNED: DLT  
 DRAWN: DLT  
 REVIEWED: RCS  
 APPROVED: RCS

DATE: DECEMBER 1999  
 SCALE: 1" = 50'-0"  
 SHEET NO. **6**

**GRW**  
 GRW Engineers, Inc.  
 Engineers, Architects, Planners  
 LEXINGTON LOUISVILLE NASHVILLE INDIANAPOLIS

U:\2788\0401\2788-06.dwg Thu Apr 20 13:43:52 2000