

OHQC1 STRENGTH HISTORY 2023 TO 2025

Plant	Sample Date	Mix Code	Ticket Number	Specified Strength	Customer Description	Mix Description	4 Day	7 Day	14 Day	28 Day	Slump (in)	Air (%)
422	10/15/2025	OHQC1CM422	972836	4000	RACK & BALLAUER EXC CO INC	QC1		3580	4550	4800	3	7
031	9/29/2025	OHQC131L	331992	4000	HEAVY HIGHWAY CONSTR CO LLC	QC1		2970	3650	4410	6	8
422	9/26/2025	OHQC1422	971909	4000	FORD DEVELOPMENT	QC1		2940	3970	5040	5	7
433	8/1/2025	OHQC1433	455531	4000	SECURITY FENCE GROUP	QC1		4240		5700	4.25	6.2
433	7/30/2025	OHQC1433	455496	4000	SECURITY FENCE GROUP	QC1		3290		5030	3.5	6.8
431	7/22/2025	OHQC1431	436511	4000	COMPLETE GENERAL CONSTRUCTION	QC1		2970		4840	6	6.1
095	4/15/2025	OHQC195K	688629	4000	BCC	QC1			4270	4920	5.25	6.2
433	3/26/2025	OHQC1433	453439	4000	MILLER BROTHERS CONST INC	QC1		2250		3620	6.5	8.5
433	3/20/2025	OHQC1433	453324	4000	MILLER BROTHERS CONST INC	QC1		2100		4210	6.25	7
051	10/18/2024	OHQC151L	501151	4000	CITY WIDE ASPHALT & CONSTR LLC	QC1		3320		5450	4.5	4.5
063	9/26/2024	OQC1P63PAV	605866	4000	JRJ	QC1P		3915	4840	4920	2.25	6.6
063	9/25/2024	OQC1P63PAV	605792	4000	JRJ	QC1P		3940	4240	5020	1.5	5.9
432	6/13/2024	OHQC1432	446035	4000	COMPLETE GENERAL CONSTRUCTION	QC1		3940		5650	5	5.9
051	8/8/2023	OHQC151L	504659	4000	R B JERGENS	QC1		3810		5390	4	5.6
433	8/3/2023	OHQC1433	452528	4000	KELCHNER INC	QC1		2460		4020	4	6.4
051	7/20/2023	OHQC151L	503873	4000	R B JERGENS	QC1		3260		4780	4	5.5
051	7/18/2023	OHQC151L	503739	4000	R B JERGENS	QC1		3470		5450	4	4.7
433	7/6/2023	OHQC1P433	452015	4000	R B JERGENS	QC1		3170		4990	5	6.3
051	5/15/2023	OHQC151L	501240	4000	R B JERGENS	QC1		3200		5180	4	5
								COMPRESSIVE				
								FLEX				
									3268	4253	4917	
									507	604	665	