

	Placement Date	Open Date	Cure Time (prior to opening)	PCJMF	# of Tickets	Total Number of Cracks	Current Cracks after Repairs	Percent of Ramp Placed	Panels Placed	Percent Panels Cracked	Finishing Equipment	Evap.	Tickets Out of Spec 499.06-1 Agg.	Tickets Out of Spec 499.06-1 Cement	Tickets Out of Spec 499.06-1 Pozzolan (cumulative)	Percent of Loads Out of Spec
DAY 1	8/15/2024	8/27/2024	12	C750291P1A	6	1	0	4.84%	38	2.63%	Roller Screed	0.1	0	0	4	66.67%
DAY 2	8/20/2024	8/27/2024	7	C750291P1A	20	27	11	16.13%	38	71.05%	Roller Screed	0.15	0	0	7	35.00%
DAY 3	9/9/2024	9/30/2024	21	C750291P1A	29	3	3	23.39%	50	6.00%	Slip Form	0.2	0	0	18	62.07%
DAY 4	9/10/2024	9/30/2024	20	C750291P1A	24	25	23	19.35%	51	49.02%	Roller Screed	0.07	0	0	12	50.00%
DAY 5	9/12/2024	9/30/2024	18	C750291P1A	6	0	0	4.84%	9	0.00%	Roller Screed	0.13	0	0	4	66.67%
DAY 6	9/15/2024	9/30/2024	15	C75029MS1B	2	0	0	1.61%			Roller Screed	0.18	0	0	0	0.00%
DAY 7	9/16/2024	9/30/2024	14	C75029MS1B	6	1	1	4.84%	36	2.78%	Roller Screed	0.17	0	0	0	0.00%
DAY 8	9/17/2024	9/30/2024	13	C750291P1A	18	1	1	14.52%	57	1.75%	Slip Form	0.07	0	1	6	33.33%
DAY 9	9/19/2024	9/30/2024	11	C750291P1A	3	0	0	2.42%	5	0.00%	Roller Screed	0.06	0	1	3	100.00%
DAY 10	9/20/2024	9/30/2024	10	C750291P1A	11	2	2	8.87%	28	7.14%	Roller Screed	0.06	0	2	7	81.82%
DAY 11	9/23/2024	9/30/2024	7	C75029MS1B	3	0	0	2.42%	60	0.00%	Roller Screed	0.03	0	0	0	0.00%
DAY 12	9/25/2024	9/30/2024	5	C75029MS1B	2	0	0	1.61%	4	0.00%	Roller Screed	0.04	0	0	0	0.00%

C750291P1A	Number of Tickets	117
C75029MS1B	Number of Tickets	13

Number of cracks	59	40
Number of cracks	1	1

Out of Spec	0	4	61
Out of Spec	0	0	0

Percent of Ramp Cracked	16%
Percent of Ramp - Single Lane	30%
Percent of Single Lane Cracked	8%
Percent of Ramp - Two Lane	70%
Percet of Two Lane Cracked	30%
Percent of Ramp Placed with Roller Screed	72%
Percent of Cracking - Roller Screed	93%
Percent of Ramp Placed with Slip Form Paver	28%
Percent of Cracking - Slip Form Paver	7%
Percent of Ramp Places on 8/20 & 9/10	35%
Percent of Cracking - 8/20 & 9/10 Placements	78%