From: Office of Contracts <Do.Not.Reply@dot.state.oh.us>
Sent: Wednesday, September 14, 2022 12:32 PM
To: DOT Cen Contracts AddendaD05
Cc: DOT Prebid
Subject: Prebid Question for 220501, PID 102530

Project Number: 220501
PID: 102530
Question Number Counter: 5
Letting Date: 9/15/2022

Company: SMCi
Question:
Question #3 reply to see sheet 20 of 21 is for GUE IR70-9.43L, Ref #10 is for COS US36-24.42L. Again where is the repair welding to take place at COS 36 structure? There is no note on the plan sheets for COS US36 indicating repair welding. Will these need to be tested as well? Clarification for bidding.

Reason Code: 08-Clarification

Click here to view this item

Please address the following Prebid Question as soon as possible, but no later than 2 working days from today's date. If the question will require a change to the contract documents (an addendum), you must respond within 2 working days that an addenda is forthcoming. All Prebid Questions submitted prior to 10AM, 4 working days prior to the bid opening require a response. Prebid Questions submitted after 10AM, 4 working days prior to a bid opening must be accepted and reviewed and a response should be provided if possible.

Reponses to any Prebid Questions that require Central Office input (i.e. DBE/EDGE Goal, Contractor % of Work, Website Issues) and addenda should be sent to Prebid@dot.state.oh.us.