



Location 1
 Primary Encloser #
 1887025758948
 3-2 AL (A,B,C) JK
 Replace Entire Span

ODOT widening road, and reshaping final grade.
 New conductor/conduit to be bored along with spare cond
 Bore new conduits 5' deeper than existing conduits.
 Abandon old conduits encased in concrete.

Location 2
 Primary Encloser #
 1886284758405
 3-2 AL (A,B,C) JK
 Replace Entire Span

A DDS Worksketch

Date Requested:		Bucket Truck?: YES	
Date Required: 05/25/2023		Truck to Site?: YES	
Job Name: Lower Three Phase Primary UG SEE DOCUMENTS			4WD?: NO
Location: FRA-161-15.80			County: FRANKLIN
Division: OP	District: 036 - Columbus NE	Crew HQ: 11469	Station No.: MORSE RD Circuit No.: 5806
W/R#: 84334773	WO#: DOP0373163	Sta/Circuit Name: MORSE RD / 5806	
JU Proposal(s):		Voltage: 12kV	Map: COLUMBUS
R/W#:		Phases: THREE (A,B,C)	Quad:
Comments:	Date: 3/30/2023	Print#:	Scale: 1:201
	Drawn By: Josh Tabor		Page: Page 1 of 1