Gmail

Val Goldfeder <vgoldfeder@teceng.com>

# Fwd: [EXTERNAL] Harrison Avenue and Stone Drive Pole Conflicts

1 message

**Andrew Sant** <asant@teceng.com>
To: Val Goldfeder <vgoldfeder@teceng.com>

Wed, Jun 1, 2022 at 7:38 AM

**Andrew Sant**, **PE** | Design Engineer

**TEC Engineering, Inc.** | 7288 Central Parke Blvd., Mason, OH 45040
**office** 513.771.8828 | **direct** 513.701.9824 | **fax** 513.771.0707
**email** asant@teceng.com | **website** www.teceng.com

---------- Forwarded message ---------
From: **Tepe, Chris** <Chris.Tepe@duke-energy.com>
Date: Fri, May 27, 2022 at 11:38 AM
Subject: RE: [EXTERNAL] Harrison Avenue and Stone Drive Pole Conflicts
To: asant@teceng.com <asant@teceng.com>
Cc: Wright, Aaron M <Aaron.Wright@duke-energy.com>

Good morning Andrew,

The only issues found with Duke's facilities to the proposed signal poles/mast arms was a neutral and a secondary that will need to be raised for clearance.

Thanks,

**Chris Tepe**

**Sr. T&D Design Technician – OH/KY North**

**Customer Delivery – Asset Design**

Office - 513-514-8209

Cell - 513-250-6851

Email - Chris.Tepe@Duke-Energy.com

**Download our new "Duke Energy Builder" app available now on Apple and Google Play stores**

Builders, Contractors, and Developers: Click here to learn Duke's requirements for new installations.

Click here to pay a Construction Invoice

Need help finding a qualified home repair contractor? Click here and check out our Find-it-Duke tool & we'll help you find one:

---

**From:** Andrew Sant <asant@teceng.com>
**Sent:** Monday, May 23, 2022 10:05 AM
**To:** Wright, Aaron M <Aaron.Wright@duke-energy.com>
**Subject:** [EXTERNAL] Harrison Avenue and Stone Drive Pole Conflicts

*** **CAUTION! EXTERNAL SENDER *** STOP. ASSESS. VERIFY!!** Were you expecting this email? Are grammar and spelling correct? Does the content make sense? Can you verify the sender? If suspicious report it, then do not click links, open attachments or enter your ID or password.

Good Morning,

We submitted plans last October for the intersection of Harrison Avenue and Stone Drive to you to confirm that our design would not be in conflict with any of your existing infrastructure. I was just following up to confirm that there would be no conflict with the design. The plans may have been modified since then and I have attached an updated plan and elevation view as well. If you have any other questions or issues, please let me know.

Thank you,

**Andrew Sant, PE** | Design Engineer

**TEC Engineering, Inc.** | 7288 Central Parke Blvd., Mason, OH 45040
**office** 513.771.8828 | **direct** 513.701.9824 | **fax** 513.771.0707
**email** asant@teceng.com | **website** www.teceng.com