



Transmittal

411 Holtzman Avenue, Columbus, OH 43205

PROJECT: DGL-WIL-127-12.43/15.09 PID DATE: 7/9/2025
114748
1025099173

SUBJECT: 114748 WIL-127-12.43/15.09 TRANSMITTAL ID: 00001
SUE Deliverable

PURPOSE: For your use and distribution VIA: Info Exchange

FROM

NAME	COMPANY	EMAIL	PHONE
Michael Simpson 411 Holtzman Avenue Columbus OH 43205 United States	SAM, LLC	Michael.Simpson@sam.biz	614-948-0187

TO

NAME	COMPANY	EMAIL	PHONE
rlumbrezer@dgl-ltd.com		rlumbrezer@dgl-ltd.com	

REMARKS: Good afternoon RJ,

Please see link above to SUE deliverables including Drawing, and Signed/Sealed Test Hole Reports. During our SUE investigations we encountered some complications with excavations. We encountered ground water while attempting to expose the Water line on the south side of the crossing. We were able to probe the water line to establish an elevation. During excavations on the Sanitary Force Main on the south side of the crossing we encountered what we believe to be a 12" Storm Pipe above the 8" Force Main. In addition the hole was caving in due to material being pea gravel. We were able to probe the Force Main to establish an elevation. Even though we ran into some obstacles, we were able to collect data on all of the requested utilities. During your review, if you have any questions, please don't hesitate to reach out.

Thank you!
Michael Simpson
Phase Manager
SAM, LLC

Transmittal

DATE: 7/9/2025
TRANSMITTAL ID: 00001

DESCRIPTION OF CONTENTS

QTY	DATED	TITLE	NOTES
1	6/24/2025	DGL - WIL - 127 - 12.43-15.09 PID 114748 Basemap.dgn	
1	7/9/2025	DGL - WIL - 127 - 12.43-15.09 PID 114748 Test Hole Reports.pdf	
1	7/9/2025	DGL - WIL - 127 - 12.43-15.09 PID 114748 Test Hole Reports.xlsx	

COPIES:

Michael Wine	(SAM, LLC)
Michael Simpson	(SAM, LLC)
Joe Costell	(SAM, LLC)