


# CONSOLIDATION TEST REPORT



Natural		Dry Dens. (pcf)	LL	PI	Sp. Gr.	USCS	AASHTO	Initial Void Ratio
Saturation	Moisture							
98.4 %	25.7 %	99.3	67	40	2.72	CH	A-7-6(47)	0.709

### MATERIAL DESCRIPTION

Fat clay

**Project No.** 0121-  
**Project:** SCI-823-0.00

**Client:** TranSystems, Inc.

**Source:** B-2

**Sample No.:** P-1

**Elev./Depth:** 6.0

**Remarks:**  
Specific Gravity= 2.72



Figure