


CONSOLIDATION TEST REPORT



| | | | | | | | | |
|------------|----------|--------------------|----|----|---------|------|-----------|-----------------------|
| Natural | | Dry Dens. (pcf) | LL | PI | Sp. Gr. | USCS | AASHTO | Initial Void Ratio |
| Saturation | Moisture | | | | | | | |
| | | 86.9 | 59 | 34 | | CH | A-7-6(40) | |

MATERIAL DESCRIPTION

Fat clay

Project No. 0121-
Project: SCI-823-0.00

Client: TranSystems, Inc.

Remarks:

Source: C-22

Sample No.: P-1

Elev./Depth: 22



Figure