

**Proposal Addendum
for
SCI-823-BUILDING DEMO; PID 89386
Project 142001**

Completion Date Change: No

Bid Item Changes, Additions or Deletions: No

Funding Splits Required: No

Please be advised of the following:

Add the following Note: No

Plan sheets:

1. Sheet 8/34 - Revised removal item number R-8 by removing the text “ Above Ground Propane Tank”. The propane tank will be removed by the owner of the tank prior to work beginning on the site by the demolition contractor.

Answers to Prebid Questions: Yes

Q1: Is the cost to remove the under ground storage tanks on the Marathon Gas Station(page 21) property to be included in the cost for ref no. 15? If so is there any information as to the size of the tanks to be removed?

A1:Yes, the cost to remove the underground storage tanks is included in proposal reference number 15. There are 4 underground storage tanks: 1- 10,000 gallon, 2- 6,000 gallon & 1- 2,000 gallon.