

SUPPLEMENTAL SUE LEVEL 'B' REPORT
SCI-823-10.13 PHASE 2 PID79977

SUMMARY:

Columbus Engineering Consultants, Inc. (CEC) performed SUE Level 'B' services for the referenced project in which all utility records, cad maps and correspondence provided by DLZ Corporation were reviewed together with extended utility research by CEC. This information was then utilized to field verify existing utilities and field mark them to be surveyed by DLZ. A sweep of the areas with proposed construction was performed in an attempt to find underground utilities that were not of record with the above-described effort. A final meeting in the field with the surveyors from DLZ was conducted to confirm all of the locations of the utilities that could be verified.

SPECIAL NOTES:

Flatwood Fallen Timbers Road

CEC met with Scioto County Water Dept. in the field to discuss the location of the water lines within the project limits.

AT&T line was marked and added to the other utilities.

Morris Lane-Blue Run Road

CEC had the Scioto County Water Dept. expose the water lines at a couple of locations providing positive verification for the surveyors from DLZ to include into their survey.

Frontier Communications line was marked and added to the other utilities.

Fairgrounds Road

AT&T line was marked and added to the other utilities.

U.S. Route 23 / Flatwood Fallen Timber Road

Underground electric between 2 billboards was marked and added to the other utilities.

AT&T line marked and added to other utilities as follows:

From west e/p of road to the west for approximately 1200 feet
Could not get signal to crossing U.S. Rt. 23, railroad and to Fairgrounds Road.
Picked up signal again east of Fairgrounds Road to approximately 4,000 feet east of Fairgrounds Road.

Then we picked up signal again crossing perpendicular to proposed alignment approximately 950 feet northwesterly of Flatwood Fallen Timber Road.

- The above AT&T line is believed to be abandoned after a discussion with Tony Lyle with HLG Engineering who was referred to us by David Scott with AT&T Ohio. Tony had stated that most of the cable was removed except at road & creek crossings. He also recommended that further inquiries should be directed to Pat Bryant with AT&T (pb2573@att.com or (678) 627-5334). We marked what we could and made no further inquiry.

Blue Run Road

Attempted to locate any lines to the gas well on the State of Ohio property. Received multiple signals and marked the four strongest signals.

Gas line from the trailers northwest to the mobile home was marked and added to the other utilities.

Gas line and underground electric line from the block building to the house was marked and added to the other utilities.

Gas line to the house that was removed was marked and added to the other utilities.