



\*NOTE  
 -THE IRONTON - PORTSMOUTH 69,000V LINE IS BEING DESIGNED ROAD ELEVATION OF 593' AT RAMP B AND 595' AT RAMP A; EXCEEDING THIS ROAD ELEVATION MAY REQUIRE THE LINE TO BE REDESIGNED.  
 - THE CLEARANCE LINE SHOWN REPRESENTS THE MINIMUM REQUIRED CLEARANCE FOR THE 12,000V DISTRIBUTION LINE

# PRELIMINARY- NOT FOR CONSTRUCTION

REV	REVISION DESCRIPTION	DATE	BY
XX	ABC	XXXXXX	XXX

SCALE:  
 200.0 ft. Horiz. Scale  
 40.0 ft. Vert. Scale

OHIO  
 SCIOTO  
 PORTSMOUTH  
 SR823  
 OHIO POWER CO

THIS DRAWING IS THE PROPERTY OF AMERICAN ELECTRIC POWER AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE COPIED OR REPRODUCED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF AMERICAN ELECTRIC POWER, OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

IRONTON - PORTSMOUTH 69,000V LINE  
 PORTSMOUTH BYPASS

SHEET LENGTH: XXXXX

	ENGR: KCI 07/17/2014	APPROVED: PRELIM 07/17/2014	SCALE: H: 1" = 200' V: 1" = 40'
	DRAWN: KCI 07/17/2014	LINE: 6-055	EQUIP: TLN160:06055
	CHECKED: XYZ dd/mm/yy	DWG: XXXX	SHEET: 1 OF 1