



*NOTE
 -THE LUCASVILLE - SARGENTS 138KV LINE IS BEING DESIGNED FOR A ROAD ELEVATION OF 705'. EXCEEDING THIS ROAD ELEVATION MAY REQUIRE THE LINE TO BE REDESIGNED.
 - THE SPECIFIED DASHED LINE SHOWS THE MINIMUM GROUND CLEARANCE FOR A 138,000V LINE.
 - ALL STRUCTURES SHOWN ARE LOCATED OUTSIDE OF DOT ROW

PRELIMINARY- NOT FOR CONSTRUCTION

REV	REVISION DESCRIPTION	DATE	BY
1	Road Elevation at 705	06/23/2014	XXX

SCALE:
 200.0 ft. Horiz. Scale
 40.0 ft. Vert. Scale

OHIO
 SCIOTO
 LUCASVILLE
 OHIO POWER COMPANY

SHEET LEN0000XXX

*THIS DRAWING IS THE PROPERTY OF AMERICAN ELECTRIC POWER AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE COPIED OR REPRODUCED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF AMERICAN ELECTRIC POWER, OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.

LUCASVILLE - SARGENTS 138,000V LINE
 ODOT - PORTSMOUTH BYPASS PROJECT



ENGINEER: KCI 07/17/2014	APPROVED: PRELIM dd/mm/yy	SCALE: H: 1" = 200' V: 1" = 40'
DRAWN BY: KCI 07/17/2014	LINE: 0-076	EQUIP: TLN160:00076
CHECKED BY: XYZ dd/mm/yy	DWS: XXXX	SHEET: 1 OF 1 REV X