



NOTE: IF EXISTING SERVICE CONNECTION IS FOUND TO BE GALVANIZED OR LEAD REPLACE FROM CORPORATION STOP TO CURB VALVE.

WATER SERVICE CONNECTION EXTENSION OR REPLACEMENT FOR 1" & SMALLER

- NOT TO SCALE -