



April 29, 2024

Patrick Schwan  
Project Manager  
Wallace Pancher Group  
29 North Park Street  
Mansfield, OH 44902  
(419) 524-0074 x 205 (Office)

**Subject: Asbestos Inspection of CUY 00077 15620 I-77 Bridge over E 22<sup>nd</sup> Street (SFN #1806874 / PID #119380) in Cleveland, Ohio 44115  
L&A Project No: 23-0495**

Patrick Schwan,

On March 18<sup>th</sup> and 19<sup>th</sup>, 2024, Mr. Will Arnold, Ohio Environmental Protection Agency (OEPA) Certified Asbestos Hazard Evaluation Specialist (AHES OH #545305) and Mr. Jason Matyac (AHES OH #547527) of Lawhon & Associates, Inc (L&A) conducted an asbestos survey of CUY 00077 15620 I-77 Bridge over E 22<sup>nd</sup> Street (SFN #1806874 / PID #119380) in Cleveland, Ohio 44115. The purpose of the survey was to determine the presence of asbestos-containing materials (ACM) located on the structure.

The survey consisted of an inspection of all accessible areas of the bridge to determine the presence, location, and quantities of asbestos-containing materials. Bulk samples were collected from suspect materials that could potentially be impacted during demolition/renovation work activities. Energized electrical components, utility conduits, and materials encased in concrete were not sampled as part of this effort. A diagram of the bridge and asbestos bulk sampling locations can be found in Appendix B. There were no bridge plans available for review. This document is not to be construed as a remediation design, and any contractors bidding on the work should conduct their own field verification of locations and quantities of any identified ACM prior to bidding.

### Suspect Materials

The materials suspected of containing asbestos identified during the survey, along with an indication of their friability, are presented in Table 1.

**Table 1: Suspected Materials**

Material	Locations	Friability
Paint on Concrete	Below Deck	Non-Friable
Paint on Steel	Below Deck	Non-Friable
Abutment Pad	Below Deck	Non-Friable

**Table 1 (continued): Suspected Materials**

<b>Material</b>	<b>Locations</b>	<b>Friability</b>
Bolt Caulking	Above Deck	Non-Friable
Parapet Pad	Above Deck	Non-Friable

### Sample Descriptions, Locations and Results

Sample descriptions, locations, and asbestos content, as determined by Polarized Light Microscopy (PLM), are presented in Table 2.

**Table 2: Sample Descriptions, Locations and Results**

<b>Sample #</b>	<b>Sample Description and Location</b>	<b>Asbestos %</b>
1	Paint on Concrete – South Side, East End, Below Deck	No Asbestos Detected
2	Paint on Concrete – South Side, West End, Below Deck	No Asbestos Detected
3	Paint on Concrete – North Side, West End, Below Deck	No Asbestos Detected
4	Paint on Steel – North Side, East End, Below Deck	No Asbestos Detected
5	Paint on Steel – South Side, West End, Below Deck	No Asbestos Detected
6	Paint on Steel – South Side, East End, Below Deck	No Asbestos Detected
7	Abutment Pad – South Side, East End, Below Deck	No Asbestos Detected
8	Abutment Pad – South Side, West End, Below Deck	No Asbestos Detected
9	Abutment Pad – North Side, West End, Below Deck	No Asbestos Detected
10	Bolt Caulking – South Side, West End	No Asbestos Detected
11	Bolt Caulking – South Side, Middle	No Asbestos Detected
12	Bolt Caulking – South Side, East End	No Asbestos Detected
13	Parapet Pad – South Side, West End	No Asbestos Detected
14	Parapet Pad – South Side, Middle	No Asbestos Detected
15	Parapet Pad – South Side, East End	No Asbestos Detected

### Materials Identified as Asbestos-Containing

Under the current EPA/NESHAP regulations, materials that contain greater than 1% asbestos are considered to be an asbestos-containing material (ACM). None of the materials sampled were found to be Asbestos Containing Material as defined by U.S EPA/NESHAP regulations.

### Attachments

Appendix A contains the Ohio Environmental Protection Agency Certifications for Mr. Will Arnold and Mr. Jason Matyac.

Appendix B contains the Bulk Sample Diagram.


Appendix C contains the laboratory results and chain-of-custody documentation for the asbestos bulk samples collected.

Appendix D contains the partially completed Ohio Environmental Protection Agency Notification of Demolition and Renovation Form filled out per ODOT direction and guidance dated July 1, 2023. The Owner and/or selected demolition/renovation contractor is responsible for completion and submission of the final notification form.

### Summary

On March 18<sup>th</sup> and 19<sup>th</sup>, 2024, Mr. Will Arnold, Ohio Environmental Protection Agency (OEPA) Certified Asbestos Hazard Evaluation Specialist (AHES OH #545305) and Mr. Jason Matyac (AHES OH #547527) of Lawhon & Associates, Inc (L&A) conducted an asbestos survey of CUY 00077 15620 I-77 Bridge over E 22<sup>nd</sup> Street (SFN #1806874 / PID #119380) in Cleveland, Ohio 44115. The purpose of the survey was to determine the presence of asbestos-containing materials (ACM) located on the structure. This document is not to be construed as a remediation design, and any contractors bidding on the work should conduct their own field verification of locations and quantities of ACM prior to bidding. No Asbestos Containing Materials (ACM) were identified in the course of the survey. If you have any questions, please contact Matt Geiger at (614) 481-8600.

Sincerely,



Matt Geiger, AHES 35832  
Project Manager



Will Arnold, AHES 545305  
Environmental Scientist

**APPENDIX A**  
**OHIO ENVIRONMENTAL PROTECTION AGENCY CERTIFICATIONS**



**Mike DeWine**, Governor  
**Jon Husted**, Lt. Governor  
**Anne M. Vogel**, Director

5/30/2023

William Arnold  
Lawhon & Associates, Inc.  
1441 King Avenue  
Columbus, OH 43212

RE: Evaluation Specialist  
Certification Number: ES545305  
Expiration Date: 6/22/2024

Dear William Arnold:

This letter and enclosed certification card approves your request to be certified as an asbestos Evaluation Specialist. You must present your card upon request at any project site while performing duties. Copies of cards are not acceptable as proof of certification.

This certification may be revoked by the Director of the Ohio Environmental Protection Agency (EPA) for violation of any of the requirements of 3745-22 or 3745-20 of the Ohio Administrative Code.

If you have any questions, please contact the Asbestos Program at 614-644-0226 or by email at [asbestoslicensing@epa.ohio.gov](mailto:asbestoslicensing@epa.ohio.gov).

Sincerely,

*Brandon M. Schwendeman*

Brandon Schwendeman  
Manager, Business Operations Support Section  
Ohio EPA - Division of Air Pollution Control



1 • P.O. Box 1049 • Columbus, OH 43216-1049  
) 644-3020 • (614) 644-3184 (fax)



# **The InService Training Network**

## **Asbestos Building Inspector and Management Planner Refresher Courses**



**Will Arnold**

has successfully completed the Asbestos Building Inspector and Management Planner Refresher Courses and passed by at least 70% the course examinations for accreditation under Section 206 of the Toxic Substance Control Act, Title II, and Indiana 326 IAC 18-2  
Provided by: The InService Training Network, Inc., 705D Lakeview Plaza Blvd, Worthington, OH 43085 (614) 436-0980

**Course Dates: February 21, 2024**

**Examination Date: February 21, 2024**

**Course Instructor:**

  
Frank Rowe

**Course Location: Worthington, Ohio**

**Expiration Date: February 21, 2025**

**Certificate Numbers: ITNIR7559 & ITNMPR7559**





State of Ohio  
Environmental Protection Agency  
Asbestos Program

Asbestos Hazard Evaluation Specialist

Jason  
Matyac



Lawhon & Associates, Inc.  
1441 King Avenue  
Columbus OH 43212



Certification Number    Expiration Date  
**ES547527**                      **10/17/24**

DOB: 6/15/95  
Card not Valid  
if Altered



# **The InService Training Network**

## **Asbestos Building Inspector and Management Planner Refresher Courses**




### **Jason Matyac**

has successfully completed the Asbestos Building Inspector and Management Planner Refresher Courses and passed by at least 70% the course examinations for accreditation under Section 206 of the Toxic Substance Control Act, Title II, and Indiana 326 IAC 18-2  
Provided by: The InService Training Network, Inc., 705D Lakeview Plaza Blvd, Worthington, OH 43085 (614) 436-0980

**Course Dates:** July 19, 2023

**Course Instructor:**

  
Kurt Varga

**Expiration Date:** July 19, 2024

**Examination Date:** July 19, 2023

**Course Location:** Worthington, Ohio





**Certificate Numbers:** ITNIR7444 & ITNMPR7444

ITN

ITN



**APPENDIX B**  
**BULK SAMPLE DIAGRAM**



**Lawhon & Associates, Inc.**  
ENVIRONMENTAL CONSULTING AND ENGINEERING SERVICES

Columbus  
 Cleveland  
 Dayton  
 Cincinnati

**Bulk Sample Diagram**

**Inventory Bridge Number:** CUY 00077 15620  
**Structure File Number:** 1806874  
**Date Sampled:** March 18 & 19, 2024  
**Surveyors:** Will Arnold, AHES #545305  
 Jason Matyac, AHES #547527

**Signature:**


*Will Arnold* *Jason Matyac*

Page 1 of 2


1441 King Avenue | Columbus, Ohio 43212 | P: 614.481.8600 | F: 614.481.8610 | www.lawhon-assoc.com



**Figure 5: View of Bridge Deck**



**Figure 6: View of Paint on Concrete & Steel**




**Figure 7: View of Bridge Abutment**



**Figure 8: View of Underside of Bridge**





Lawhon & Associates, Inc.

ENVIRONMENTAL CONSULTING AND ENGINEERING SERVICES

Columbus

Cleveland

Dayton



**Bulk Sample Diagram**

**Inventory Bridge Number:** CUY 00077 15620

**Structure File Number:** 1806874

**Date Sampled:** March 18 & 19, 2024

**Surveyors:** Will Arnold, AHES #545305  
Jason Matyac, AHES #547527

**Signature:**  


Page 2 of 2

1441 King Avenue | Columbus, Ohio 43212 | P: 614.481.8600 | F: 614.481.8610 | [www.lawhon-assoc.com](http://www.lawhon-assoc.com)

**APPENDIX C**  
**LABORATORY RESULTS AND CHAIN OF CUSTODY**





**The Identification Specialists**

Analysis Report  
prepared for  
Lawhon & Associates, Inc.

**Report Date: 3/27/2024**

**Project Name: CUY 00077 15620**

**Project #: 23-0495**

**SanAir ID#: 24016680**



NVLAP LAB CODE 600227-0

11709 Chesterdale Road | Cincinnati, Ohio 45246  
888.895.1177 | 513.438.6006 | [IAQ@SanAir.com](mailto:IAQ@SanAir.com) | [SanAir.com](http://SanAir.com)



SanAir ID Number

24016680

FINAL REPORT

3/27/2024 4:41:20 PM

**Name:** Lawhon & Associates, Inc.

**Address:** 1441 King Ave

Columbus, OH 43212

**Phone:** 614-481-8600 ext. 142

**Project Number:** 23-0495

**P.O. Number:**

**Project Name:** CUY 00077 15620

**Collected Date:** 3/18/2024 - 3/19/2024

**Received Date:** 3/22/2024 10:10:00 AM

Dear Matt Geiger,

We at SanAir would like to thank you for the work you recently submitted. The 15 sample(s) were received on Friday, March 22, 2024 via UPS. The final report(s) is enclosed for the following sample(s): 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

A handwritten signature in black ink that reads "Maureen Y. Haley". The signature is written in a cursive style.

Maureen Y. Haley  
Asbestos Laboratory Manager  
SanAir Technologies Laboratory

Final Report Includes:

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

Sample conditions:

- 15 samples in Good condition.





SanAir ID Number

24016680

FINAL REPORT

3/27/2024 4:41:20 PM

Name: Lawhon & Associates, Inc.

Address: 1441 King Ave

Columbus, OH 43212

Phone: 614-481-8600 ext. 142

Project Number: 23-0495

P.O. Number:

Project Name: CUY 00077 15620

Collected Date: 3/18/2024 - 3/19/2024

Received Date: 3/22/2024 10:10:00 AM

Analyst: Pinkerton, Sid

## Asbestos Bulk PLM EPA 600/R-93/116

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
1 / 24016680-001 Paint on Concrete, South Side, East End	Grey Non-Fibrous Homogeneous		100% Other	None Detected
2 / 24016680-002 Paint on Concrete, South Side, West End	Grey Non-Fibrous Homogeneous		100% Other	None Detected
3 / 24016680-003 Paint on Concrete, North Side, West End	Grey Non-Fibrous Homogeneous		100% Other	None Detected
4 / 24016680-004 Paint on Steel, North Side, East End	Brown Non-Fibrous Homogeneous		100% Other	None Detected
5 / 24016680-005 Paint on Steel, South Side, West End	Brown Non-Fibrous Homogeneous		100% Other	None Detected
6 / 24016680-006 Paint on Steel, South Side, East End	Brown Non-Fibrous Homogeneous		100% Other	None Detected
7 / 24016680-007 Abutment Pad, South Side, East End	Brown Non-Fibrous Heterogeneous		100% Other	None Detected
8 / 24016680-008 Abutment Pad, South Side, West End	Brown Non-Fibrous Heterogeneous		100% Other	None Detected
9 / 24016680-009 Abutment Pad, North Side, West End	Brown Non-Fibrous Heterogeneous		100% Other	None Detected
10 / 24016680-010 Bolt Caulking, South Side, West End	Tan Non-Fibrous Homogeneous		100% Other	None Detected

Analyst: *Sidney Pinkerton*

Approved Signatory: *Johnathan Wilson*

Analysis Date: 3/27/2024

Date: 3/27/2024



SanAir ID Number

24016680

FINAL REPORT

3/27/2024 4:41:20 PM

**Name:** Lawhon & Associates, Inc.**Address:** 1441 King Ave

Columbus, OH 43212

**Phone:** 614-481-8600 ext. 142**Project Number:** 23-0495**P.O. Number:****Project Name:** CUY 00077 15620**Collected Date:** 3/18/2024 - 3/19/2024**Received Date:** 3/22/2024 10:10:00 AM

Analyst: Pinkerton, Sid

**Asbestos Bulk PLM EPA 600/R-93/116**

SanAir ID / Description	Stereoscopic	Components		Asbestos Fibers
	Appearance	% Fibrous	% Non-fibrous	
11 / 24016680-011 Bolt Caulking, South Side, Middle, Caulking	Tan Non-Fibrous Homogeneous		100% Other	None Detected
11 / 24016680-011 Bolt Caulking, South Side, Middle, Mastic	Black Non-Fibrous Homogeneous		100% Other	None Detected
12 / 24016680-012 Bolt Caulking, South Side, East End	Tan Non-Fibrous Homogeneous		100% Other	None Detected
13 / 24016680-013 Parapet Pad, South Side, West End	Various Non-Fibrous Heterogeneous		100% Other	None Detected
14 / 24016680-014 Parapet Pad, South Side, Middle	Various Non-Fibrous Heterogeneous		100% Other	None Detected
15 / 24016680-015 Parapet Pad, South Side, East End	Various Non-Fibrous Heterogeneous		100% Other	None Detected

Analyst:

Approved Signatory:

Analysis Date: 3/27/2024

Date: 3/27/2024

### **Disclaimer**

The final report cannot be reproduced, except in full, without written authorization from SanAir. This report is the sole property of the client named on the SanAir Technologies Laboratory chain-of-custody (COC). Results in the report are confidential information intended only for the use by the client named on the COC. Neither results nor reports will be discussed with or released to any third party without our client's written permission to assure that parts of the report are not taken out of context and to maintain client confidentiality. The information provided in this report applies only to the samples submitted in the condition they were received at the laboratory and is relevant only for the date, time, and location of sampling. Samples were received in good condition unless otherwise noted on the report. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client, which includes the project name, project number, po number, sample collection dates, special instructions, samples collected by, sample numbers, sample identifications/ location, sample type, selected analysis type, and total area or volume that may affect the validity of the results. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. SanAir assumes no responsibility or liability for the manner in which results are used or interpreted. This report does not constitute and shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, AIHA LAP, LLC or any other agency of the U.S. government. Samples are held for a period of 60 days.

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

Asbestos Accreditations, Licenses, or Certificates

NVLAP Lab Code 600227-0

State of Rhode Island Department of Health, Certification Number: PLM00144, TEM00144

State of West Virginia Bureau for Public Health, Analytical Laboratory Number: LT000637





Lawhon & Associates, Inc.

1441 King Avenue  
Columbus, OH 43212  
Phone: (614) 481-8600  
Fax: (614) 481-8610

Sent To: San Air

VIA: UPS

Date: 3-18/19-24

24016680

No. 4538

Page 1 of 1

Turn around:

5-day

Page 6 of 6

## ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY RECORD

Project Name: <u>CVY 00077 15620</u>		Project No.: <u>23-0495</u>		Project Contact: <u>Matt Geiger</u>		Sampler (print): <u>Will Arnold</u>		Signature <u>Will Arnold</u>	
Sample I.D. No.	Homog. Area No.	Sample /Homogeneous Area Description	Sample Location		Remarks				
1	1	Paint on concrete	South side, East End		Below Deck				
2	1	├	West End		├				
3	1		North Side		├				
4	2		North Side, East End		Below Deck				
5	2	├	South Side, West End		├				
6	2		East End		├				
7	3		South Side, East End		├				
8	3	├	West End		├				
9	3		North Side		├				
10	4		South Side, West End		├				
11	4	├	Middle		├				
12	4		East End		├				
13	5		West End		├				
14	5	├	Middle		├				
15	5		East End		├				
SAMPLE ANALYSIS BY EPA METHOD 600/R-93/116 UNLESS OTHERWISE NOTED.									
<input type="checkbox"/> Stop 1st Positive <input checked="" type="checkbox"/> Analyze All Samples									
Relinquished by: (signature) <u>Will Arnold</u>		Date / Time <u>3-21 1700</u>		Received by: (signature) <u>RMB</u>		Date / Time <u>3/22/19 10:10 am</u>		Relinquished by: (signature)	
								Date / Time	

**APPENDIX D**  
**OHIO ENVIRONMENTAL PROTECTION AGENCY**  
**NOTICE OF DEMOLITION AND RENOVATION**



# Notification of Demolition and Renovation/Abatement

## Section 1: General Information

Division of Air Pollution Control

Work on projects cannot begin until 10 working days after a COMPLETE original notification form, **including payment**, is submitted to Ohio EPA. Instructions and a worksheet for fee calculation are available at [epa.ohio.gov/asbestos](http://epa.ohio.gov/asbestos). This form can be completed, and payment made, at [ebiz.epa.ohio.gov](http://ebiz.epa.ohio.gov). Questions? [asbestos@epa.ohio.gov](mailto:asbestos@epa.ohio.gov) or (614) 466-0061.

Ohio EPA Use Only	Notification #:	Postmarked: / /	Received: / /	<input type="checkbox"/> Hand-Delivered
-------------------	-----------------	-----------------	---------------	---

### 1) Notification Information (Check all that apply)

<input checked="" type="checkbox"/> Original	<input type="checkbox"/> Revision # (count):	<input type="checkbox"/> Installation	<input type="checkbox"/> Emergency	<input type="checkbox"/> Annual	<input type="checkbox"/> Cancellation	County: Cuyahoga
--	--	---------------------------------------	------------------------------------	---------------------------------	---------------------------------------	------------------

### 2) Owner, Asbestos Abatement Contractor, Billing and Fire Department Information

Revised? ☐

Owner		
Name: ODOT District 12		Is this a company? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Address: 5500 Transportation Boulevard		Contact Person: Mark Carpenter
City: Garfield Heights	State: Ohio	Zip: 44125
Email: mark.carpenter@dot.ohio.gov	Phone: (216) 584-2089	Fax:
Asbestos Abatement Contractor (if applicable)		
Name:	License #: AC	Expiration Date: / /
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -
Billing Contact		
Is this contact associated with the <input type="checkbox"/> Owner, <input type="checkbox"/> Asbestos Abatement Contractor, or <input type="checkbox"/> Demolition Contractor (if not installation)?		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -
Fire Department (if applicable)		
Name:		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -

### 3) Ohio Asbestos Hazard Evaluation Specialist and Evaluation Procedure

Revised? ☐

Evaluation Specialist: Will Arnold	Certification #: ES 545305	Expiration Date: 6/22/2024
Procedure, including analytical methods, employed to detect the presence of and to estimate the quantity of regulated asbestos-containing material (RACM) and Category I and Category II non-friable asbestos-containing material: <input checked="" type="checkbox"/> PLM <input type="checkbox"/> Point Count <input type="checkbox"/> TEM <input type="checkbox"/> Other Method (Explain Below):		

### 4) Procedures to be followed should unexpected RACM be discovered (check all that apply)

Revised? ☐

<input checked="" type="checkbox"/> Stop work and keep wet	<input checked="" type="checkbox"/> Evacuate area	<input checked="" type="checkbox"/> Demarcate area	<input checked="" type="checkbox"/> Contact licensed abatement contractor
<input checked="" type="checkbox"/> Contact district office/local air authority			
<input type="checkbox"/> Other (Explain):			

### 5) Planned Demolition (check all that apply)

Revised? ☐

Describe demolition work to be performed and method(s) to be employed, including demolition techniques to be used: <input type="checkbox"/> Implosion <input type="checkbox"/> Fire Training <input type="checkbox"/> Wet Methods <input type="checkbox"/> Manual Demolition <input type="checkbox"/> Mechanical Demolition <input type="checkbox"/> Other (Explain):	
Description of affected facility components (include attachment if necessary):	



Mail completed form and payment to:  
Ohio EPA, DAPC – Asbestos  
50 W. Town St., 7<sup>th</sup> Floor or P.O. Box 1049  
Columbus, OH 43216-1049

# Notification of Demolition and Renovation/Abatement

## Section 1: General Information

Continued

### 6) Asbestos Description and Engineering Controls (if asbestos is being abated)

Revised? ☐

For the material listed in each project, describe the type(s) of ACM to be abated, engineering controls and work practices to be used to minimize emissions and ensure proper waste handling:

Type of ACM to be abated:	<input type="checkbox"/> Surfacing	<input type="checkbox"/> Mechanical	<input type="checkbox"/> Other		
Engineering Controls:	<input type="checkbox"/> Wet Methods	<input type="checkbox"/> Glove Bag	<input type="checkbox"/> NPE	<input type="checkbox"/> AFD	<input type="checkbox"/> Other:
Work Practices:	<input type="checkbox"/> Intact Removal	<input type="checkbox"/> Manual	<input type="checkbox"/> Mechanical	<input type="checkbox"/> Other:	

### 7) Asbestos Waste Transporter (if applicable)

Revised? ☐

Transporter #1 Name:		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -
Transporter #2 Name (if applicable):		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -

### 8) Asbestos Waste Disposal Site (if applicable)

Revised? ☐

Name:		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -

### 9) Emergency Demolition (complete if you checked "Emergency" above and "Demolition" for any project)

Revised? ☐

A copy of the issued order, including the following information, **must be attached** to this notification.

Government Official Issuing Order:	Title:
Agency:	Authority of Order (Citation of Code):
Date of Order: / /	Demolition Date: / /

### 10) Emergency Renovation/Abatement (complete if you checked "Emergency" above and "Renovation/Abatement" for any project)

Revised? ☐

Date of Emergency: / /	Time of Emergency: : <input type="checkbox"/> a.m. <input type="checkbox"/> p.m.
Description of Sudden, Unexpected Event:	
Explanation of how the event caused unsafe conditions or equipment damage:	

### 11) Attestation

Revised? ☐

In accordance with Ohio Administrative Code rule 3745-20-03(A)(4)(p), I certify that at least one person trained as required by paragraph (B) of rule 3745-20-04 of the Administrative Code will supervise the stripping and removal described by this notification. I acknowledge that the submission of false or misleading statements is prohibited by law and I certify that facts contained in this notification are true, accurate, and complete.

Signature:	Date: / /
Name:	Title:
Organization:	

# Notification of Demolition and Renovation/Abatement

## Section 2: Project Address Specific Information

Division of Air Pollution Control

Please complete Section 2 for the address included with this notification. If the project is an "Installation" per OAC 3745-20, complete a separate Section 2 page for each address associated with this notification.

Ohio EPA Use Only Project ID #:

### A. Facility Description

Revised? ☐

Building Name (if applicable): CUY 00077 15620		Site Location (specific): 1.53 Mi. N. Of Jct. Sr-14 [41°29'30.27"N 81°40'20.92"W]	
Address: I-77 Bridge over E 22 <sup>nd</sup> St		County: Cuyahoga	
City: Cleveland	State: OH	Zip: 44115 -	
Building Size (square feet): 24,003	No. of Floors: 1	Age: 62	
Present Use: Bridge		Prior Use: Bridge	

### B. Type of Operation (check all that apply)

Revised? ☐

<input checked="" type="checkbox"/> Demolition	<input type="checkbox"/> Renovation/Abatement – Type: <input type="checkbox"/> Removal <input type="checkbox"/> Repair <input type="checkbox"/> Encapsulation <input type="checkbox"/> Enclosure
--	--

### C. Asbestos Present (check one)

Revised? ☐

<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> No, previously abated	Year Abated:
------------------------------	--	--	--------------

### D. Approximate Amount of Asbestos-Containing Materials (complete table below and Section 1 #6 if asbestos is present)

Revised? ☐

	Material to be Removed			Material NOT to be Removed	
	RACM	Non-friable Asbestos-Containing Material		Non-friable Asbestos-Containing Material	
		Category I	Category II	Category I	Category II
Pipes (linear feet)					
Surface area on other facility components (ft²)					
Volume if length or area cannot be measured (ft³)					

### E. Asbestos Abatement Schedule and Abatement Specialist (original notification is required 10 working days prior to the start of work)

Revised? ☐

Setup Date: / /			Abatement Date: / /			Complete Date: / /	
(Shift 1) Time start/end on site	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Abatement Specialist Name:	Certification #: AS			Expiration Date: / /			
(Shift 1) Time start/end on site	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Abatement Specialist Name:	Certification #: AS			Expiration Date: / /			

### F. Demolition Contractor (if applicable)

Revised? ☐

Name:		
Address:		Contact Person:
City:	State:	Zip: -
Email:	Phone: ( ) -	Fax: ( ) -

### G. Demolition Schedule (original notification is required 10 working days prior to the start of work)

Revised? ☐

Start Date: / /	Complete Date: / /
-----------------	--------------------

### H. Project Hold

Revised? ☐

Hold Begin Date: / /	Work Resume Date: / /
----------------------	-----------------------