



















SYMBOLS LEGEND			
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	1-400 WATT HPS, TYPE III DISTRIBUTION, 54.7' M.H. LOW MAST, ARROW INDICATES AIMING OF LIGHT FIXTURE		PROPOSED PULL BOX
	1-310 WATT HPS, TYPE III DISTRIBUTION, 41.7' M.H. CONVENTIONAL		EXISTING PULL BOX
	1-310 WATT HPS, TYPE III DISTRIBUTION, 41.7' M.H. CONVENTIONAL WITH GLARE SHIELD		PROPOSED MEDIAN PULL BOX
	EXISTING LIGHT POLE AND LUMINAIRE		EXISTING POWER SERVICE, 240 VOLT, 3 WIRE, GROUNDED NEUTRAL
	EXISTING UTILITY POLE		SYMBOL WITH "X" INDICATES ITEM TO BE DEMOLISHED
			EXISTING OVERHEAD TELEPHONE
			EXISTING LIGHTING CIRCUIT TO REMAIN
			EXISTING LIGHTING CIRCUIT TO BE ABANDONED
			EXISTING UNDERGROUND ELECTRIC TO REMAIN
			PROPOSED LIGHTING CIRCUIT #4 AWG, TICK MARKS INDICATE QUANTITY OF CONDUCTORS, #2 INDICATES CONDUCTOR SIZE IF OTHER THAN #4 AWG
			PROPOSED LIGHTING CIRCUIT IN 3" CONDUIT
			PROPOSED LIGHTING CIRCUIT IN 4" CONDUIT, IN BARRIER
			2" CONDUIT STUB-OUT