July 1, 2024

David James
Consultant Contract Manager
Ohio Department of Transportation District 4
2088 South Arlington Road
Akron, Ohio 44306
(Office) 330-786-3100

Subject: Asbestos Inspection of SUM 00480 07450 L Interstate Route 480 Bridge

over Stow Road (SFN #7710445 / PID 111186) in Hudson, Ohio 44236.

L&A Project No: 24-0045 Task 7

Mr. David James,

On June 24, 2024, Mr. Matt Geiger, Ohio Environmental Protection Agency (OEPA) Certified Asbestos Hazard Evaluation Specialist (AHES OH #35832) and Mr. Will Arnold (AHES OH #545305) of Lawhon & Associates, Inc (L&A) conducted an asbestos survey SUM 00480 07450 L Interstate Route 480 Bridge over Stow Road (SFN #7710445 / PID 111186) in Hudson, Ohio 44236. The purpose of the survey was to determine the presence of asbestos-containing materials (ACM) located on the structure.

The survey consisted of an inspection of all accessible areas of the bridge to determine the presence, location, and quantities of ACM. Bulk samples were collected from suspect materials that could potentially be impacted during demolition/renovation work activities. Energized electrical components, utility conduits, and materials encased in concrete were not sampled as part of this effort. A diagram of the bridge and asbestos bulk sampling locations can be found in Appendix B. There were no bridge plans available for review. This document is not to be construed as a remediation design, and any contractors bidding on the work should conduct their own field verification of locations and quantities of any identified ACM prior to bidding.

Suspect Materials

The materials suspected of containing asbestos identified during the survey, along with an indication of their friability, are presented in Table 1.

Table 1: Suspected Materials

Material	Locations	Friability
Paint on Concrete	Above/Below Deck	Non-Friable
Preformed Expansion Pad	Above Deck	Non-Friable
Parapet Expansion Pad	Above Deck	Non-Friable
Reflector Mastic	Above Deck	Non-Friable

1441 King Avenue | Columbus, Ohio 43212 | P: 614.481.8600 | F: 614.481.8610 | www.lawhon-assoc.com

Sample Descriptions, Locations and Results

Sample descriptions, locations, and asbestos content, as determined by Polarized Light Microscopy (PLM), are presented in Table 2.

Table 2: Sample Descriptions, Locations and Results

Sample #	Sample Description and Location	Asbestos %
20240624-1	Paint on Concrete – Below Deck, West Side, North End	No Asbestos Detected
20240624-2	Paint on Concrete – Below Deck, East Side, North Pillar	No Asbestos Detected
20240624-3	Paint on Concrete – Below Deck, East Side, Middle Pillar	No Asbestos Detected
20240624-4	Preformed Expansion Pad – West End, North Side	No Asbestos Detected
20240624-5	Preformed Expansion Pad – West End, North Side	No Asbestos Detected
20240624-6	Preformed Expansion Pad – West End, South Side	No Asbestos Detected
20240624-7	Parapet Expansion Pad – South Side, East End	No Asbestos Detected
20240624-8	Parapet Expansion Pad – South Side, Middle	No Asbestos Detected
20240624-9	Parapet Expansion Pad – South Side, West End	No Asbestos Detected
20240624-10	Reflector Mastic – South Side, East End	No Asbestos Detected
20240624-11	Reflector Mastic – South Side, Middle	No Asbestos Detected
20240624-12	Reflector Mastic – South Side, West End	No Asbestos Detected

Materials Identified as Asbestos-Containing

Under the current EPA/NESHAP regulations, materials that contain greater than 1% asbestos are considered to be an ACM. None of the materials sampled were found to be ACM as defined by U.S EPA/NESHAP regulations.

Attachments

Appendix A contains the Ohio Environmental Protection Agency Certifications for Mr. Matt Geiger and Mr. Will Arnold.

Appendix B contains the Bulk Sample Diagram.

Appendix C contains the laboratory results and chain-of-custody documentation for the asbestos bulk samples collected.

Appendix D contains the partially completed Ohio Environmental Protection Agency Notification of Demolition and Renovation Form filled out per ODOT direction and guidance dated July 1, 2023. The Owner and/or selected demolition/renovation contractor is responsible for completion and submission of the final notification form.

Summary

On June 24, 2024, Mr. Matt Geiger, Ohio Environmental Protection Agency (OEPA) Certified Asbestos Hazard Evaluation Specialist (AHES OH #35832) and Mr. Will Arnold (AHES OH #545305) of L&A conducted an asbestos survey of SUM 00480 07450 L Interstate Route 480 Bridge over Stow Road (SFN #7710445 / PID 111186) in Hudson, Ohio 44236. The purpose of the survey was to determine the presence of asbestos-containing materials (ACM) located on the structure. This document is not to be construed as a remediation design, and any contractors bidding on the work should conduct their own field verification of locations and quantities of ACM prior to bidding. No ACM were identified in the course of the survey. If you have any questions, please contact Matt Geiger at (614) 481-8600.

Sincerely,

Matt Geiger, AHES 35832

Moth K Feiger

Project Manager

Will Arnold, AHES 545305 Environmental Scientist

JU Ams

APPENDIX A OHIO ENVIRONMENTAL PROTECTION AGENCY CERTIFICATIONS

State of Ohio Environmental Protection Agency Asbestos Program

Asbestos Hazard Evaluation Specialist

Matthew A Geiger



Lawhon & Associates, Inc.
1441 King Avenue rotaction Agency
Columbus OH 43212

Certification Number Expiration Date

ES35832

10/14/24



DOB: 10/1/93

Asbestos Building Inspector and Management Planner Refresher Courses

The InService Training Network



Matthew Geiger

has successfully completed the Asbestos Building Inspector and Management Planner Refresher Courses and passed by at least 70% the course examinations for accreditation under Section 206 of the Toxic Substance Control Act, Title II, and Indiana 326 IAC 18-2
Provided by: The InService Training Network, Inc., 705D Lakeview Plaza Blvd, Worthington, OH 43085 (614) 436-0980

Course Dates: February 21, 2024

Course Instructor:

Frank Rowe

Expiration Date: February 21, 2025

Examination Date: February 21, 2024

Course Location: Worthington, Ohio

Certificate Numbers: ITNIR7560 & ITNMPR7560



Mike DeWine, Governor Jon Husted, Lt. Governor Anne M. Vogel, Director

5/28/2024

William Arnold Lawhon & Associates, Inc. 1441 King Avenue Columbus, OH 43212

RE:

Evaluation Specialist

Certification Number: ES545305 Expiration Date: 6/22/2025

Dear William Arnold:

This letter and enclosed certification card approves your request to be certified as an asbestos Evaluation Specialist. You must present your card upon request at any project site while performing duties. Copies of cards are not acceptable as proof of certification.

This certification may be revoked by the Director of the Ohio Environmental Protection Agency (EPA) for violation of any of the requirements of 3745-22 or 3745-20 of the Ohio Administrative Code.

If you have any questions, please contact the Asbestos Program at 614-644-0226 or by email at asbestoslicensing@epa.ohio.gov.

Sincerely,

Brandon W. Schwendeman

Brandon Schwendeman

Manager, Business Operations Support Section Ohio EPA - Division of Air Pollution Control

State of Ohio Environmental Protection Agency Asbestos Program

Asbestos Hazard Evaluation Specialist

William Arnold



Lawhon & Associates, Inc. 1441 King Avenue corection Agency Columbus OH 43212

Certification Number Expiration Date

6/22/25 ES545305



The InService Training Network

Asbestos Building Inspector and Management Planner
Refresher Courses



Will Arnold

has successfully completed the Asbestos Building Inspector and Management Planner Refresher Courses and passed by at least 70% the course examinations for accreditation under Section 206 of the Toxic Substance Control Act, Title II, and Indiana 326 IAC 18-2

Provided by: The InService Training Network, Inc., 705D Lakeview Plaza Blvd, Worthington, OH 43085 (614) 436-0980

Course Dates: February 21, 2024

Course Instructor: Fire Range

Frank Rowe

Expiration Date: February 21, 2025

Examination Date: February 21, 2024


Course Location: Worthington, Ohio


Certificate Numbers: ITNIR7559 & ITNMPR7559







APPENDIX B BULK SAMPLE DIAGRAM






















APPENDIX C LABORATORY RESULTS AND CHAIN OF CUSTODY



The Identification Specialists

Analysis Report prepared for Lawhon & Associates, Inc.

Report Date: 6/28/2024

Project Name: SUM-00480-07450-L

Project #: 24-0045 Task 7

SanAir ID#: 24035326



NVLAP LAB CODE 600227-0

11709 Chesterdale Road I Cincinnati, Ohio 45246 888.895.1177I 513.438.6006 I IAQ@SanAir.com I SanAir.com



SanAir ID Number
24035326
FINAL REPORT
6/28/2024 5:19:37 PM

Name: Lawhon & Associates, Inc.

Address: 1441 King Ave

Columbus, OH 43212

Phone: 614-481-8600 ext. 142

Project Number: 24-0045 Task 7

P.O. Number:

Project Name: SUM-00480-07450-L

Collected Date: 6/24/2024

Received Date: 6/26/2024 10:00:00 AM

Dear Matt Geiger,

We at SanAir would like to thank you for the work you recently submitted. The 12 sample(s) were received on Wednesday, June 26, 2024 via UPS. The final report(s) is enclosed for the following sample(s): 20240624-1, 20240624-2, 20240624-3, 20240624-4, 20240624-5, 20240624-6, 20240624-7, 20240624-8, 20240624-9, 20240624-10, 20240624-11, 20240624-12.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

Maureen Y. Haley

Asbestos Laboratory Manager SanAir Technologies Laboratory

Marren G. Heales

Final Report Includes:

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

Sample conditions:

- 12 samples in Good condition.



SanAir ID Number
24035326
FINAL REPORT
6/28/2024 5:19:37 PM

Name: Lawhon & Associates, Inc.

Address: 1441 King Ave

Columbus, OH 43212 **Phone:** 614-481-8600 ext. 142

Project Number: 24-0045 Task 7

P.O. Number:

Project Name: SUM-00480-07450-L

Collected Date: 6/24/2024

Received Date: 6/26/2024 10:00:00 AM

Analyst: Pinkerton, Sid

Asbestos Bulk PLM EPA 600/R-93/116

	Stereoscopic	Com	ponents	
SanAir ID / Description	Appearance	% Fibrous	% Non-fibrous	Asbestos Fibers
20240624-1 / 24035326-001 Paint on Concrete, Below Deck, West End, North	Various Non-Fibrous Heterogeneous		100% Other	None Detected
20240624-2 / 24035326-002 Paint on Concrete, Below Deck, East Side, Pillar	Various Non-Fibrous Heterogeneous		100% Other	None Detected
20240624-3 / 24035326-003 Paint on Concrete, Below Deck, Middle, Pillar	Various Non-Fibrous Heterogeneous		100% Other	None Detected
20240624-4 / 24035326-004 Preformed Expansion Pad, West End, North Side	Black Fibrous Homogeneous	80% Cellulose	20% Other	None Detected
20240624-5 / 24035326-005 Preformed Expansion Pad, West End, North Side	Black Fibrous Homogeneous	80% Cellulose	20% Other	None Detected
20240624-6 / 24035326-006 Preformed Expansion Pad, West End, South Side	Black Fibrous Homogeneous	80% Cellulose	20% Other	None Detected
20240624-7 / 24035326-007 Parapet Expansion Pad, South Side, East End	Tan Non-Fibrous Homogeneous		100% Other	None Detected
20240624-8 / 24035326-008 Parapet Expansion Pad, South Side, Middle	Tan Non-Fibrous Homogeneous		100% Other	None Detected
20240624-9 / 24035326-009 Parapet Expansion Pad, South Side, West End	Tan Non-Fibrous Homogeneous		100% Other	None Detected
20240624-10 / 24035326-010 Reflector Mastic, South Side, East End	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

Analyst:

Sidney Kirkerton

Approved Signatory:

Date:

6/28/2024



SanAir ID Number 24035326 FINAL REPORT 6/28/2024 5:19:37 PM

Name: Lawhon & Associates, Inc.

Address: 1441 King Ave

Columbus, OH 43212

Phone: 614-481-8600 ext. 142

Project Number: 24-0045 Task 7

P.O. Number:

Project Name: SUM-00480-07450-L

Collected Date: 6/24/2024

Received Date: 6/26/2024 10:00:00 AM

Analyst: Pinkerton, Sid

Analysis Date:

Asbestos Bulk PLM EPA 600/R-93/116

	Stereoscopic	Com	ponents	
SanAir ID / Description	Appearance	% Fibrous	% Non-fibrous	Asbestos Fibers
20240624-11 / 24035326-011 Reflector Mastic, South Side, Middle	Yellow Non-Fibrous Homogeneous		100% Other	None Detected
20240624-12 / 24035326-012 Reflector Mastic, South Side, West End	Yellow Non-Fibrous Homogeneous		100% Other	None Detected

Analyst: Sidney Kinkerten Approved Signatory:

6/27/2024

6/28/2024 Date:

Disclaimer

The final report cannot be reproduced, except in full, without written authorization from SanAir. This report is the sole property of the client named on the SanAir Technologies Laboratory chain-of-custody (COC). Results in the report are confidential information intended only for the use by the client named on the COC. Neither results nor reports will be discussed with or released to any third party without our client's written permission to assure that parts of the report are not taken out of context and to maintain client confidentiality. The information provided in this report applies only to the samples submitted in the condition they were received at the laboratory and is relevant only for the date, time, and location of sampling. Samples were received in good condition unless otherwise noted on the report. Fibers smaller than 5 microns cannot be seen with this method due to scope limitations. The accuracy of the results is dependent upon the client's sampling procedure and information provided to the laboratory by the client, which includes the project name, project number, po number, sample collection dates, special instructions, samples collected by, sample numbers, sample identifications/ location, sample type, selected analysis type, and total area or volume that may affect the validity of the results. SanAir assumes no responsibility for the sampling procedure and will provide evaluation reports based solely on the sample and information provided by the client. SanAir assumes no responsibility or liability for the manner in which results are used or interpreted. This report does not constitute and shall not be used to claim product certification, approval, or endorsement by NVLAP, NIST, AIHA LAP, LLC or any other agency of the U.S. government. Samples are held for a period of 60 days.

Polarized- light microscopy is not consistently reliable in detecting asbestos in floor covering and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-asbestos containing.

Asbestos Accreditations, Licenses, or Certificates

NVLAP Lab Code 600227-0

State of Rhode Island Department of Health, Certification Number: PLM00144, TEM00144

State of West Virginia Bureau for Public Health, Analytical Laboratory Number: LT000637

Rev#01 2/3/2023 Page 5 of 6

Lawhon & Associates, Inc.

1441 King Avenue

TTT FRING AVOING	
Columbus, OH 43212	
Phone: (614) 481-8600	
Fax: (614) 481-8610	

Sent To: Sun AIR	24035326 No. 5338	0 Jo 6 of
VIA: VIS	Page of	D C
Date: Object / 2024	Turn around:	

ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY RECORD

Project Name:			Project No.:	Proj	ject Contact:			Sampler (prin	nt):		Signature
SUM-00480-	67US	0-L	24-0045 Task	7 M	latt G	riger				*	MAGN
Sample I.D. No.	Homog. Area No.	Sample /Homo	ogeneous Area Description			Sample	e Location				Remarks
20240624-1		Paint on	Concrete	· · · · · · · · · · · · · · · · · · ·	Below D				orth		
1 -7	1	1				, E	ast s	side Pil	lar		
-3	l	7			7		7:23/5	J:9:1	lar		
-4	ζ	brokonny E	xpansion pad		wist B	N. lon:	rorth	<u>'side</u>			
-2	2				1		<u> </u>				
-6	して		<u></u>		7	<u>, 'So</u>	N.K.	2:10			
-7	3	Paralet E	tlansion lad		500th	5:de,	East	End			
-8	3		\		1	•	middle				
-9	3		<u></u>	-		` \	~05A				
-10	4	Reflector	Mastic	_			2 ast	End			
-11	4						W-7 910				
7 -12	4						~ 151 W	END			
								<u>-</u>			
							-				

							-	-			
								-			
								•			, <u>, , , , , , , , , , , , , , , , , , </u>
SAMPLE ANALYSIS BY POINT COUNT FRIABLI				ED.						☐ Stop 1st Posi	tive Analyze All Samples
Relinquished by: (signature)		ate / Time Received b	y: (signature)	Date / Time	Relinquished	d by: (signature) Da	ate / Time	Receive	ed by: (signature)	Date / Time

APPENDIX D OHIO ENVIRONMENTAL PROTECTION AGENCY NOTICE OF DEMOLITION AND RENOVATION



Notification of Demolition and Renovation/Abatement Section 1: General Information

Division of Air Pollution Control

Work on projects cannot begin until 10 working days after a COMPLETE original notification form, including payment, is submitted to Ohio EPA. Instructions and a worksheet for fee calculation are available at epa.ohio.gov/asbestos. This form can be completed, and payment made, at *ebiz.epa.ohio.gov*. Questions? *asbestos@epa.ohio.gov* or (614) 466-0061.

Ohio EPA Use Only	Notification #:		Postmar	ked: /	/		Received:	/ /		☐ Hand-D	elivered
1) Notification Info	rmation (Check all tha	t apply)									
Original Re	vision # (count):	☐ Installation	Emerg	gency	Annual	Са	ancellation	County: Su	ımmit		
2) Owner, Asbestos	Abatement Contracto	r, Billing and Fire De	epartment	t Informat	ion						Revised?
Owner											
Name: ODOT District	4							l:	s this a con	npany? 🛚 Y	es No
Address: 2088 S. Arlir	ngton Road				Conta	ct Person	: Ed Deley (DEC)			
City: Akron				State: Oh	io			Zip: 44	306		
Email: Ed.Deley@dot.ohio.gov Phone: 330-786-3100 Fax:											
Asbestos Abatement (Contractor (if applicabl	e)									
Name:					License	#: AC			Expiration	n Date: /	/
Address:					Conta	ct Person	ı:				
City:				State:				Zip:	-		
Email:				Phone: ()	-		Fax: ()	-	
Billing Contact											
Is this contact associa	ted with the 🔲 Owne	er, 🗌 Asbestos Aba	atement C	ontractor,	or De	molition	Contractor (if not insta	allation)?		
Address:					Conta	ct Person	1:				
City:				State:				Zip:	-		
Email:				Phone: ()	-		Fax: ()	-	
Fire Department (if ap	oplicable)										
Name:											
Address:					Conta	ct Person	ı:				
City:				State:				Zip:	-		
Email:				Phone: ()	-		Fax: ()	-	
3) Ohio Asbestos Ha	azard Evaluation Speci	alist and Evaluation	Procedure	e							Revised?
Evaluation Specialist:	Matt Geiger			C	ertificatio	n#: ES 3	5832	Expir	ation Date	: 10/14/2024	
_	analytical methods, em ory II non-friable asbest		-	of and to			ity of regulant TEN			ning material (d (Explain Bel	
4) Procedures to be	followed should unex	pected RACM be di	scovered (check all t	hat apply)					Revised?
Stop work and kee	ep wet 🛛 Ev	acuate area		Demarcate	area		⊠ Co	ntact licer	sed abater	ment contract	or
Contact district of	ffice/local air authority										
Other (Explain):											
5) Planned Demoliti	ion (check all that app	ly)									Revised?
	vork to be performed a Fire Training	, ,					•	sed: Other (Ex	plain):		
Description of affected	d facility components (include attachment	if necessa	ry):							

Notification of Demolition and Renovation/Abatement

Section 1: General Information

Continued

Mail completed form and payment to: Ohio EPA, DAPC – Asbestos 50 W. Town St., 7th Floor or P.O. Box 1049 Columbus, OH 43216-1049

6) Asbestos Description and	l Engineering Controls (i	f asbestos is being al	bated)							Revised?
For the material listed in each ensure proper waste handling		pe(s) of ACM to be ab	oated, engineer	ring co	ontrols and work	practices to	be use	d to mini	mize em	issions and
Type of ACM to be abated:	Surfacing	☐ Mechanical	☐ Other							
Engineering Controls:	☐ Wet Methods	Glove Bag	☐ NPE	□ NPE □ AFD □ Oth			:			
Work Practices:	☐ Intact Removal	☐ Manual	☐ Mechar	nical	Other:					
7) Asbestos Waste Transpo	rter (if applicable)									Revised?
Transporter #1 Name:										
Address:				Con	tact Person:					
City:			State:			Zip	o:	-		
Email:			Phone: ()	-	Fa	x: ()	-	
Transporter #2 Name (if appli	cable):									
Address:				Con	tact Person:					
City:			State:			Zip	o:	-		
Email:			Phone: ()	-	Fa	x: ()	-	
8) Asbestos Waste Disposal	Site (if applicable)									Revised?
Name:										
Address:				Contact Person:						
City:			State:	State: Zip: -						
Email:			Phone: ()	-	Fa	x: ()	-	
9) Emergency Demolition (c	complete if you checked	"Emergency" above	and "Demoliti	on" fo	or any project)					Revised?
A copy of the issued order, inc	cluding the following info	ormation, must be at	tached to this r	notific	ation.					
Government Official Issuing O	rder:		Title:							
Agency:			Authority	Authority of Order (Citation of Code):						
Date of Order: / /			Demoliti	on Da	te: / /					
10) Emergency Renovation/	Abatement (complete if	you checked "Emerg	ency" above a	nd "Re	enovation/Abat	ement" for a	ny pro	ject)		Revised?
Date of Emergency: / /	<u>'</u>		Time of	Emerg	gency: :	a.m] p.m.			
Description of Sudden, Unexp	ected Event:									
Explanation of how the event	caused unsafe condition	ns or equipment dam	age:							
11) Attestation										Revised?
In accordance with Ohio Adm the Administrative Code will s is prohibited by law and I cert	supervise the stripping ar	nd removal described	by this notifica	ation.	I acknowledge t	•			•	
Signature:					Date:	: /				
Name:			Title:							
Organization:										



Notification of Demolition and Renovation/Abatement Section 2: Project Address Specific Information

Division of Air Pollution Control

Please complete Section 2 for the address included with this notification. If the project is an "Installation" per OAC 3745-20, complete a separate Section 2 page for each address associated with this notification.

Ohio EPA Use Only	Project ID #	<i>t</i> :								
A. Facility Description Revised?										
Building Name (if a	Building Name (if applicable): SUM 00480 07450 L Site Location (specific): 2.63 Mi E Of Sr 91 [41°16'37.54"N 81°24'35.33"W]								33"W]	
Address: I.R. 480 Bi	ridge over Sto	w Road				Co	ounty: Summit			
City: Hudson				State:	ОН	Ziį	p: 44236 -			
Building Size (squar	re feet): 4,28	34		No.	of Floors: 1			Age: 59		
Present Use: Bridge Prior Use: Bridge										
B. Type of Opera	B. Type of Operation (check all that apply) Revised?									
□ Demolition	Reno	ovation/Abatement – Ty	pe: 🔲 Removal	I ☐ Repa	air 🗌 Encapsu	ulation	Enclosure			
C. Asbestos Pres	sent (check or	ne)							Revised?	
☐ Yes ☐ No		No, previously abated	d Year A	bated:						
D. Approximate	Amount of As	sbestos-Containing Mat	erials (complete	table belo	w and Section 1	#6 if asbe	stos is present)		Revised?	
			Material to l	be Remove	d		М	aterial NOT to l	be Removed	
			Non-frial	ble Asbesto	s-Containing Ma	aterial	Non-fria	ble Asbestos-Co	ontaining Material	
		RACM	Catego	ry I	Catego	ory II	Cate	gory I	Category II	
Pipes (linear feet)										
Surface area on oth components (ft²)	ner facility									
Volume if length or be measured (ft ³)	area cannot									
E. Asbestos Aba	tement Sched	lule and Abatement Sp	ecialist (original r	notification	is required 10 v	working da	ays prior to the s	tart of work)	Revised?	
Setup Date: /	/	Abater	ment Date: /	/		C	Complete Date:	/ /		
(Shift 1) Time	Monday	, Tuesday	Wednes	day	Thursday	F	riday	Saturday	Sunday	
start/end on site										
Abatement Special	ist Name:	1	•	Certification #: AS			•	te: / /		
(Shift 1) Time	Monday	/ Tuesday	Wednes	day	Thursday	F	riday	Saturday	Sunday	
start/end on site										
Abatement Special	ist Name:			Certification #: AS				Expiration Date: / /		
F. Demolition C	ontractor (if a	pplicable)							Revised?	
Name:										
Address:					Contact Per	son:				
City:					•		Zip:	-		
Email:			Phone: () -		Fax	: ()	-		
G. Demolition Se	chedule (origi	nal notification is requi	red 10 working d	ays prior to	the start of wo	ork)			Revised?	
Start Date: / /				Complete Date: / /						
H. Project Hold									Revised?	
Hold Begin Date: / /					Work Resume Date: / /					